CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

To,

Date: 29-06-2019

ASSISTANT EXECUTIVE ENGINEER
HEGGANAHALLI SUB DIVISION
BBMP
BANGALORE

Dear Sir,

Sub: M/S. Civil Pro Services for the work of IMPROVEMENTS TO ROADS AT RAMAIAH BADAVANE CROSS ROADS IN WARD NO.70, RAJAGOPALANAGARA.

Ref: 1. Work Order No: EE/DD/WO/113/17-18

2. Job code: 070-18-000026

We are here with forwarding to Technical Manager (West), KRIDL. First and Final Bill duly verified and certified that the work is satisfactory and for a Gross Value of Rs.49,86,433.00 /- (Rs. Fourty Nine Lakhs Eighty Six Thousand Four Hundred and Thirty Three Rupees Only).

Thanking you,

Yours faithfully,

For Civil Pro

CIVIL Pro Sig..... Date..... BANGALORE

R RUDRAPRASAD
AUTHORIZED SIGNATORY
CIVIL PRO

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

To,

ASSISTANT EXECUTIVE ENGINEER

PEENYA INDUSTRIAL AREA SUB DIVISION

BBMP

BANGALORE

Date: 21-06-2019

Dear Sir,

Sub: M/S. Civil Pro Services for the work of FILLING POTHOLES IN WARD NO.41 PIA.

Ref: 1. Work Order No: EE/DD/WO/403/18-19

2. Job code: 041-18-000043

We are here with forwarding to Smt. Manjula K, #381, 23rd Main 2nd Stage BTM Layout Bangalore-76. First and Final Bill duly verified and certified that the work is satisfactory and for a Gross Value of Rs.30,76,212.00 /- (Rs. Thirty Lakhs Seventy Six Thousand Two Hundred and Twelve Rupees Only).

Thanking you,

Yours faithfully,

For Civil Pro

CIVIL Pro Sig..... Date..... BANGALORE

R RUDRAPRASAD
AUTHORIZED SIGNATORY
CIVIL PRO

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Scanned by CamScanner

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
CIVIL PRO
4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Date: 03/08/2019

Lab ID	:	CP-2019-09-12-33
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Roads Drains and Other Development Works in Bagalagunte Ward No.14.
Agency	:	Sri Raghunandan L, #13, 2nd Main Road,Gandhigrama Maruthi Extension, Bengaluru-21.
Customer's Reference	:	EE/DD/WO/360/19-20
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	29-07-2019
Customer ID	:	Cement Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M30 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	03/08/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M30	27/07/2019	03/08/2019	149.61 X 149.43 X 150.50	22355	8.122	580.9	26.0	25.9
2	Cement Concrete Pavement	M30	27/07/2019	03/08/2019	151.93 X 150.56 X 149.11	22874	8.619	614.6	26.9	
3	Cement Concrete Pavement	M30	27/07/2019	03/08/2019	151.57 X 151.49 X 151.07	22961	8.991	568.6	24.8	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ದಾಸರಹಳ್ಳಿ ಉಪವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig. Date.

Page 1/1
****End of Report****

Scanned by CamScanner

AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
CIVIL PRO
4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF CEMENT CONCRETE CUBES

Format No: CP/TF/01

Lab ID : CP-2019-09-12-33

Date: 24/08/2019

Customer : Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.

Address : Dasarahalli Sub Division, BBMP, Bangalore.

Project Name : Improvements to Roads Drains and Other Development Works in Bagalagunte Ward No.14.

Agency : Sri Raghunandan L, #13, 2nd Main Road,Gandhigrama Maruthi Extension, Bengaluru-21.

Customer's Reference : EE/DD/WO/360/19-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 29-07-2019

Customer ID : Cement Concrete Pavement

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 24/08/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M30	27/07/2019	24/08/2019	150.78 X 150.27 X 151.77	22658	8.592	766.2	33.8	33.4
2	Cement Concrete Pavement	M30	27/07/2019	24/08/2019	150.90 X 150.84 X 151.81	22762	8.020	745.0	32.7	
3	Cement Concrete Pavement	M30	27/07/2019	24/08/2019	151.57 X 151.74 X 150.42	22999	8.607	773.7	33.6	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST RESULTS OF GRADATION FOR GSB
(IS 2386:(Part 1) 1963 (RA2011)

Lab ID	:	**CP-RW-2019-09-12-33** **Date: 31-07-2019**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Roads Drains and Other Development Works in Bagalagunte Ward No.014.
Agency	:	Sri Raghunandan L, #13, 2nd Main Road,Gandhigrama Maruthi Extension, Bengaluru-21.
Customer Reference	:	EE/DD/WO/360/19-20
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	29-07-2019
Type of Mix	:	GSB (Granular Sub Base)
Date of test	:	29-07-2019
Oven Dry Weight	:	10000 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	% Cumulative Weight Retained	% Passing	Spec. Limit Vide Table 400.1 MORTH Specification
75	0	0	0	100	100
53	997	997	9.97	90.03	80-100
26.5	1685	2682	26.82	73.18	55-90
9.5	1292	3974	39.74	60.26	35-65
4.75	1490	5464	54.64	45.36	25-55
2.36	1764	7228	72.28	27.72	20-40
0.425	1666	8894	88.94	11.06	10-25
0.075	1106	10000	100.00	0.00	0-5

TESTS ON FILLER SCREEN MATERIALS

Sl no	Particulars	Test results	Spec.Limit Vide Table
1	Liquid Limit, %	21.33%	Maximum 25
2	Plasticity index, %	Non plastic	Maximum 6

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು
ಬ ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

FOR CIVIL Pro.
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

TEST RESULTS OF GRADATION FOR WMM

Lab ID	:	CP-RW-2019-09-12-33 **Date: 05-08-2019**
Customer	:	Assistant Executive Engineer, Dasarahalli Sub Division, BBMP, Bangalore.
Address	:	Dasarahalli Sub Division, BBMP, Bangalore.
Project Name	:	Improvements to Roads Drains and Other Development Works in Bagalagunte Ward No.014.
Agency	:	Sri Raghunandan L, #13, 2nd Main Road,Gandhigrama Maruthi Extension, Bengaluru-21.
Customer Reference	:	EE/DD/WO/360/19-20
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	03-08-2019
Type of Mix	:	WMM (Wet Mix Macadam)
Date of test	:	03-08-2019
Oven Dry Weight	:	11000 Grams

IS Sieve Size(mm)	Weight Retained (gm)	Cumulative Weight Retained (gm)	% Cumulative Weight Retained	% Passing	Spec.I.Vide Table 400.13 MORTH Specification
53	0	0	0.0	100.0	100
45	315	315	2.9	97.1	95-100
22.4	2259	2574	23.4	76.6	60-80
11.2	2179	4753	43.2	56.8	40-60
4.75	2251	7004	63.7	36.3	25-40
2.36	1621	8625	78.4	21.6	15-30
0.6	623	9248	84.1	15.9	8-22
0.075	1338	10586	96.2	3.8	0-5

Note:-

The results pertain to the samples received and tested.
All information Furnished by Customer/ Representative
Any correction in the report will make this report invalid.
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

End of Report

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner